

Date: May 07, 2024

**BOIL WATER NOTICE RESCIND**

**Beatty Water & Sanitation District**

**PWS I.D. # NV000009**

The "Precautionary Boil Water Notice" issued to the residents in the area affected by the scheduled water shut off is hereby cancelled. Bacteriological results indicate that E. Coli and other coliform bacteria are *not* present in the system.

The test results are as follows:

Sample Date	Number of Samples	Results
May 05, 2024	2	Absent
May 06, 2024	2	Absent

Sample locations were at 616 W Reibel Street and 516 W Reibel Street. The two sample locations were upstream and downstream from repair.

Signed,



**LeRoy Daines**

**Utility Services, Inc**

**775-553-2931**

**Date: 05/05/2024**