

Date: 03/17/2022

BOIL WATER NOTICE RESCIND

Beatty Water & Sanitation District

PWS I.D. # NV 000009

The "Precautionary Boil Water Notice" issued to the residents in the area affected by the water main breaks is hereby cancelled. Bacteriological results indicate that E. Coli and other coliform bacteria are *not* present in the system.

The test results are as follows:

Sample Date	Number of Samples	Results
03/14/2022	2	Absent
03/15/2022	2	Absent

Sample locations were at 1001 N C Ave. and 1151 N C Ave. The two sample locations were upstream and downstream from repair.

Signed



Lance Goodman

General Manager

lance@beattywsd.com

775-553-2931

Date: March 17, 2022